

BOARD OF
BUILDING AND SAFETY
COMMISSIONERS

MARSHA L. BROWN
PRESIDENT

VAN AMBATIELOS
VICE-PRESIDENT

VICTOR H. CUEVAS
HELENA JUBANY
ELENORE A. WILLIAMS

CITY OF LOS ANGELES
CALIFORNIA



ANTONIO R. VILLARAIGOSA
MAYOR

DEPARTMENT OF
BUILDING AND SAFETY
201 NORTH FIGUEROA STREET
LOS ANGELES, CA 90012

ROBERT R. "BUD" OVROM
GENERAL MANAGER

RAYMOND S. CHAN, P.E., S.E.
EXECUTIVE OFFICER

O'Hagin's, Inc.
210 Classic Court
Rohnert Park, CA 94928

Attn: Gregory S. Daniels
(707) 303-3660

RESEARCH REPORT: RR 25497
(CSI # 10230)

Expires: September 1, 2012
Issued Date: June 1, 2011
Code: 2011 LABC

GENERAL APPROVAL – Clerical Modification - O'Hagin Model "S" Cloaked Vent Tile for attic ventilation.

DETAILS

O'Hagin Model "S" Cloaked Vent Tiles are comprised of two pieces. A 25 ½" x 11" sub-flashing constructed of galvanized sheet steel with a formed opening covered with galvanized wire mesh for insert protection and a 25" x 19 ½" formed galvanized steel hood with two cut openings on the underside, also covered with galvanized wire mesh.

O'Hagin Model "S" Cloaked Vent Tiles can be used to provide attic ventilation for roofs and roofing structures employing clay or concrete tile roofs.

The approval is subject to the following requirements:

1. Location and specifications of O'Hagin Cloaked Vent Tile shall be shown on approved plans.
2. Installation of the O'Hagin Cloaked Vent Tile shall be in accordance with the manufacturer's written instructions and as specified herein. A copy shall be kept at the job site.
3. O'Hagin Cloaked Vent Tile vents have a rating of 95 square inches Net Free Ventilation Area and simply take the place of two roofing tiles specified for the job.
4. All O'Hagin Cloaked Vent Tiles are stamped with an identifying mark. No substitution will be accepted.
5. O'Hagin Cloaked Vent Tile shall be manufactured by O'Hagin's Inc. in sizes, styles and materials as indicated on approved plans.

RR 25497
Page 1 of 2

O'Hagin's, Inc.

RE: O'Hagin Model "S" Cloaked Vent Tile for attic ventilation

DISCUSSION

The clerical modification is to update the code to the 2011LABC.

The report is in compliance with the 2011 City of Los Angeles Building Code.

O'Hagin cloaked Vent Tile approval is based on the tests.

Addressee to whom this Research report is issued is responsible for providing copies of it, complete with any attachments indicated, to architects, engineers and builders using items approved herein in design or construction which must be approved by Department of Building and Safety Engineers and Inspectors.

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this Approval have been met in the project in which it is to be used.



WILLIAM STUTSMAN, Chief
Engineering Research Section
201 N. Figueroa St., Room 880
Los Angeles, CA 90012
Phone- 213-202-9812
Fax- 213-202-9943

KH:kh
RR25497/MSWord2007
R06/03/11
8F/1203.2/1503